

## RADDO

- Track mounted LED Cylinder  
120 VAC, 0.25A, 60 Hz, 30 W
- For use with XTS 3-Circuit GLOBAL Trac™



# Installation Instructions




Fig. 1




Fig. 2




Fig. 3

**NE PAS TOUCHER LA PUCE LED (PARTIE JAUNE) À L'INTERIEUR DU LUMINAIRE ! CELA ENDOMMAGE LE LUMINAIRE !  
DON'T TOUCH THE LED COB (YELLOW SEGMENT) INSIDE THE FIXTURE ! IT WILL DAMMAGE THE LIGHTING FIXTURE !**

Fig 1 Track light

Fig. 2 Adapter

Fig. 3 Track

## IMPORTANT SAFETY INSTRUCTIONS - SAVE THESE INSTRUCTIONS

Read all instructions before installing luminaire.


Track lighting systems are intended for installation in dry locations only (damp or wet installation will void warranty).

**Caution - To reduce the risk of fire and electric shock, use only with Track System : Nordic Aluminium / XTS 3-Circuit GLOBAL Trac™.**

### INSTALLATION

1. Insert the adapter into the track so that the asymmetric flange of the track and the corresponding groove of the adapter fit together (Step 1).
2. Make sure the adapter is in the appropriate position (Step 2).
3. Push the adapter to the track bottom and at the same time switch the locking knob on the right and the left side until it snaps to mechanically secure the track head (Step 3, 4 +5).
4. Select the desired circuit with the circuit selector knob (Step 6).
5. To remove the adapter from the track, proceed in reverse order.

Step 1



Step 2



Step 3



Step 4



Step 5



Step 6

